



Quabbin Analytical Laboratory

Box 1192 Stadler Street, Belchertown, MA 01007

(413)-323-7134

Name:	Town of Shutesbury	Sample Date:	2-23-17
Address:	1 Cooleyville Road	Report Date:	3-03-17
	Shutesbury, MA 01072	Collected By:	Rebecca Torres / A. Werner
Sample Location:		Type Supply:	Well
	Town Hall Kitchen	Sample No.:	QAL-1199 with SP-789
	1 Cooleyville Road		
	Shutesbury, MA 01072		

TESTED FOR	RESULTS	MAX. RECOMMENDED LEVELS
Total Coliform Bacteria	Absent	Absent
Fecal Coliform Bacteria	Absent	Absent
Nitrite	0	1.0 mg/l
Nitrate	1.1	10.0 mg/l
PH	7.29	6.5-8.5
Alkalinity	74.0	No Limit
Iron	.07	.30 mg/l
Manganese	.02	.05 mg/l
Copper	.06	1.3 mg/l
Sulfate	13.0	250 mg/l
Chloride	*728.0	250 mg/l
Hardness	252.0	No Limit
Conductivity	1,028.0	No Limit
Total Dissolved Solids	*678.5	500 mg/l
Turbidity	0.2	5 NTU
Chlorine	0	0
Sodium	166.0	No Limit

Results are only for those items listed above and on the above collected date. Except for the following *Chloride & Total Dissolved Solids, the sample was found to be within acceptable levels for D.E.P. Drinking Water Standards. If there are any questions on this report, please do not hesitate to call this office. **ALTHOUGH THERE IS NO LIMIT ON SODIUM, THE GUIDELING IS 20.0 MG/L**
David Fredenburgh, Director

