



# *Quabbin Analytical Laboratory*

Box 1192 Stadler Street, Belchertown, MA 01007

**(413)-323-7134**

Name:	Town of Shutesbury	Sample Date:	2-23-17
Address:	1 Cooleyville Road	Report Date:	3-03-17
	Shutesbury, MA 01072	Collected By:	Rebecca Torres / A. Werner
Sample Location:		Type Supply:	Well
	Town Hall Kitchen	Sample No.:	QAL-1199 with SP-789
	1 Cooleyville Road		
	Shutesbury, MA 01072		

TESTED FOR	RESULTS	MAX. RECOMMENDED LEVELS
<b>Total Coliform Bacteria</b>	Absent	Absent
<b>Fecal Coliform Bacteria</b>	Absent	Absent
<b>Nitrite</b>	0	1.0 mg/l
<b>Nitrate</b>	1.1	10.0 mg/l
<b>PH</b>	7.29	6.5-8.5
<b>Alkalinity</b>	74.0	No Limit
<b>Iron</b>	.07	.30 mg/l
<b>Manganese</b>	.02	.05 mg/l
<b>Copper</b>	.06	1.3 mg/l
<b>Sulfate</b>	13.0	250 mg/l
<b>Chloride</b>	*728.0	250 mg/l
<b>Hardness</b>	252.0	No Limit
<b>Conductivity</b>	1,028.0	No Limit
<b>Total Dissolved Solids</b>	*678.5	500 mg/l
<b>Turbidity</b>	0.2	5 NTU
<b>Chlorine</b>	0	0
<b>Sodium</b>	166.0	No Limit

Results are only for those items listed above and on the above collected date. Except for the following \*Chloride & Total Dissolved Solids, the sample was found to be within acceptable levels for D.E.P. Drinking Water Standards. If there are any questions on this report, please do not hesitate to call this office. **ALTHOUGH THERE IS NO LIMIT ON SODIUM, THE GUIDELING IS 20.0 MG/L**  
David Fredenburgh, Director

