



Quabbin Analytical Laboratory

Box 1192 Stadler Street, Belchertown, MA 01007

(413)-323-7134

Name:	Town of Shutesbury	Sample Date:	2-23-17
Address:	1 Cooleyville Road	Report Date:	3-03-17
	Shutesbury, MA 01072	Collected By:	Rebecca Torres / A. Werner
Sample Location:	Town Hall Well House	Type Supply:	Well
	1 Cooleyville Road	Sample No.:	QAL-1198 with SP-788
	Shutesbury, MA 01072		

TESTED FOR	RESULTS	MAX. RECOMMENDED LEVELS
Total Coliform Bacteria	Absent	Absent
Fecal Coliform Bacteria	Absent	Absent
Nitrite	0	1.0 mg/l
Nitrate	1.3	10.0 mg/l
PH	7.12	6.5-8.5
Alkalinity	72.0	No Limit
Iron	.12	.30 mg/l
Manganese	.04	.05 mg/l
Copper	.04	1.3 mg/l
Sulfate	12.0	250 mg/l
Chloride	*678.0	250 mg/l
Hardness	248.0	No Limit
Conductivity	1,061.0	No Limit
Total Dissolved Solids	*700.3	500 mg/l
Turbidity	0.2	5 NTU
Chlorine	0	0
Sodium	204.0	No Limit

Results are only for those items listed above and on the above collected date. Except for the following *Chloride, Total Dissolved Solids & Sediment, the sample was found to be within acceptable levels for D.E.P. Drinking Water Standards. If there are any questions on this report, please do not hesitate to call this office. ALTHOUGH THERE IS NO LIMIT ON SODIUM, THE GUIDELINE IS 20.0 MG/L.

David Fredenburgh, Director

